

Freeland Water and Sewer District

2021

CONSUMER CONFIDENCE REPORT

The Freeland Water and Sewer District Commissioners along with Whidbey Water Services LLC are proud to give you the Annual Drinking Water Report, which is a summary of the Freeland Water and Sewer District's drinking water quality. Safe drinking water is our primary commitment.

Why am I receiving this report?

Congress passed the "Safe Drinking Water Act" and gave the U.S. Environmental Protection Agency (EPA) the job of making rules – National Primary Drinking Water Regulations (NPDWR) – to ensure that drinking water in the U.S. is safe.

In 1996, Congress passed amendments that required drinking water systems to give consumers important information about their water, including where it comes from, what is in the water, and how your water quality compares with federal standards.

This report is brought to you in accordance with the EPA's 40 Codes of Federal Regulations, NPDWR Parts 141 and 142.

Where does our water come from?

The single available water resource in the surrounding area is ground water. At the present time your water system draws all its water from three wells.

Why must you test my water?

Drinking water, including bottled water, may reasonably be expected to contain very small amounts of some contaminants. The presence of contaminants does not necessarily mean that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800) 426-4791.

What contaminants might be in water?

Contaminants that may be present in water are microbial contaminants, inorganic contaminants, pesticides and herbicides, and organic chemical contaminants. These are tested for and all testing passed unless listed on the back of report.

- Microbial contaminants, such as viruses and bacteria, which may come from septic systems or wildlife.
- Inorganic contaminants, such as salts and metals, which can be a natural occurrence or a result from storm water runoff or domestic wastewater discharges.
- Pesticides and herbicides, which may come from a variety of sources, such as agricultural and residential uses.
- Organic chemical contaminants, which include synthetic and volatile organic chemicals, are by-products of industrial processes, and could come from urban storm water runoff, and septic systems.

Are there Contaminants in Freeland Water and Sewer District's water?

We are pleased to report that Freeland Water and Sewer District met all the federal drinking water standards last year.

However, it is not always possible to remove all contaminants. The EPA sets limits on the amount of a contaminant that can be in drinking water. Our Water Manager tests your water monthly for **coliform**, through the Distribution System, which can show the presence of microorganisms that could cause illness. We have also tested the wells for **inorganic, organic and volatile compounds, radionuclides**. **All test results met the allowable levels set by the EPA and the Washington State Department of Health. Results can be viewed online at <https://fortress.wa.gov/doh/eh/portal/odw/si/Intro.aspx>**

Is our water safe for everyone?

Some people may be more vulnerable to the drinking water contaminants than the general population. Immune-compromised persons, such as people with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA Centers for Disease Control have guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants that are available from the Safe Drinking Water hotline (800) 426-4791.

What if I have questions about my water?

Contact: Andy Campbell (Whidbey Water Services, LLC) Certified Water Distribution Manager at telephone number: (360)579-1535 or Email at: waterwork@whidbey.com.

Important Definitions:

Maximum Contaminant Level (MCL) = The highest level of a contaminant that is allowed in drinking water below which there is no known or expected risk to health.

CCRU – Consumer Confidence Report Unit, are actual units multiplied by 1000 for ease of comparison.

FREELAND WATER AND SEWER DISTRICT
WATER TEST RESULTS

<u>Substance</u>	<u>Month/ Year Sample Taken</u>	Highest Level Allowed (MCL) in CCR units	Water Level Detected in CCR units	Major Sources of Contaminant in Drinking Water
<u>Radionuclide's</u>				
Radium 228	11-16	5000	500	Erosion of Mineral deposits naturally occurring in groundwater.
<u>Disinfection By-Products</u>				
Chlorine Residual	2021	4000	400	Measure of disinfectant added to water.
Halocetic Acids	12-21	60400	290	By-product of disinfection.
Total Trihalomethanes	12-21	80400	41700	By-product of disinfection.
<u>Inorganic Contaminants</u>				
Arsenic	06-17	10	4.3	Erosion of Mineral deposits naturally occurring in groundwater. Your drinking water currently meets EPA's revised drinking water standard for arsenic. However, it does contain low levels of arsenic. There's a small chance that some people who drink water containing low levels of arsenic for many years could develop circulatory disease, cancer, or other health problems. Most types of cancer and circulatory diseases are due to factors other than exposure to arsenic. EPA's standard balances the current understanding of arsenic's health effects against the costs of removing arsenic from drinking water.
Fluoride	12-04	4000	300	Erosion of Mineral deposits naturally occurring in groundwater. Naturally present in the environment.
Nitrate	10-21	10000	2400	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Coliform	2020	1	Not detected	Measure of bacteria in water
Lead	09-20	15	Not detected	Corrosion of household plumbing fixtures. (tested in homes)
Copper	09-20	1300	310	Corrosion of household plumbing fixtures. (tested in homes)